

कार्यालय नगर परिषद टोंक

क्रमांक :- एमसीटी / 2023-24 / 13251

दिनांक :- 13/2/24

प्रमाण पत्र

प्रमाणित किया जाता है कि इमानुएल सीनियर सैकण्डरी स्कूल, न्यू बस स्टेण्ड के पास टोंक की सफाई व्यवस्था का निरीक्षण किया गया। निरीक्षण के दौरान विद्यालय परिसर एवं आस पास की सफाई व्यवस्था सही एवं सुचारू पाई गई तथा पीने हेतु स्वच्छ जल उपलब्ध करवाया जा रहा है।



स्वास्थ्य निरीक्षक
स्वास्थ्य निरीक्षक
नगर परिषद टोंक



PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT LEVEL LABORATORY, TONK
Bahir Pump House, Ghalod Road Road, Tonk- 304001

TEST REPORT

Test Report No. : PHE-TON/2024/ PHE/TON/2400020F

Issued to:

Emmanuel Senior Secondary School
Near Bus Stand
Tonk

Issue Date : 15.02.2024

District: Tonk
Block: Tonk



Format No.: PHE-TON/7.8/F-01

Ref_ID	10	Sample Code No.	N24/T-020		
Customer Reference Letter No.	1991	Source Description :	Tap		
Reference Date:	14-02-2024	Sample / Source Location :	In Campus		
Sample received on dated :	14-02-2024	Habitation/Ward No. :	Tonk		
Sample Collected by :	Beeni Thoms	Village/Colony/Nagar :	Tonk		
Design. of Sample Collector:	Manager	Gram Panchayat/City Area :	Tonk		
Sample Quantity	1 Ltr	Sample Collected on Dated :	14-02-2024		
Sample Packing	OK Condition	Date of Analysis Started :	14-02-2024		
NABL Sample Code No.	PHE/TON/24020	Dated of Analysis Completed :	15-02-2024		
IS-10500:2012 Amm.iv		Sample Report No.	20		
Test Parameters	Requirement (Acceptable Limit)	Permissible limit in the absence of alternative sources	References Method: Protocol Used	Test Values	
1	pH @ 25± 2 °C	6.5 to 8.5	No relaxation	APHA, Edn. 23rd, 4500 H+ B	7.95
2	Temperature (°C)	-	-	APHA, Edn. 23rd, 2550 B	-
3	Total Alkalinity (as CaCO ₃) mg/l	200	600	APHA, Edn. 23rd, 2320 B	140
4	Total Hardness (as CaCO ₃) mg/l	200	600	APHA, Edn. 23rd, 2340 C	256
5	Calcium (as Ca) mg/l	75	200	APHA, Edn. 23rd, 3500 Ca B	32.06
6	Magnesium (as Mg) mg/l	30	100	APHA, Edn. 23rd, 3500 Mg B	42.77
7	Chloride (as Cl ⁻) mg/l	250	1000	APHA, Edn. 23rd, 4500 Cl B	108
8	Nitrate (as NO ₃ ⁻¹) mg/l	45	No relaxation	APHA, Edn. 23rd, 4500 No ₃ B	22.0
9	Fluoride (as F ⁻) mg/l	1.0	1.5	APHA, Edn. 23rd, 4500 F C	0.580
10	Conductivity μS/cm @ 25± 2(°C)	-	-	APHA, Edn. 23rd, , 2510 B	785
11	Sulphate (as SO ₄ ⁻²) mg/l	200	400	APHA, Edn. 23rd, 4500 SO ₄ ⁻² E	-
12	TDS mg/l @ 180 (°C)	500	2000	APHA, Edition 23rd, 2540-C	541

Sample Analysed by


JLA

Sample Not Collected By Laboratory

Authorized Signatory

(Sanjeev Kumar Meena)
Junior Chemist, Tonk



NOTE:

- 1 This test report shall not be reproduce except in full, unless permission for the reproduction of an approved abstract has been obtained from the Junior Chemist, PHED District Laboratory, Tonk
- 2 This test report relates only to the samples/items submitted to the laboratory for test and sample provided by customer
- 3 The test report can't be used for any publicity or any legal purpose.
- 4 The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
- 5 The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Telephone : 01432-248436

-----End of Test Report-----

E-mail: phedlabtonk@gmail.com
E-mail: lab.ton.phed@rajasthan.gov.in